

TYPE-EXAMINATION CERTIFICATE


Issued by Liftinstituut B.V.

- Certificate no. : NL10-400-1002-039-11/2 Revision no.: 3
- Description of the product : Printed Circuit Board Lift Control System MIKRONIK SX PLUS
- Trademark, type : Mik-EI PCB SX PLUS V1
- Name and address of the manufacturer : Mik-el Elektronik San. Tic. Ltd. Sti.
Yüzyil Mah. Matbaacilar Yolu no. 56
34200 Bagcilar, Istanbul
Turkey
- Name and address of the certificate holder : Mik-el Elektronik San. Tic. Ltd. Sti.
Yüzyil Mah. Matbaacilar Yolu no. 56
34200 Bagcilar, Istanbul
Turkey
- Certificate issued on the following requirements : Lifts Directive 2014/33/EU
EN 81-1/2:1998+A3:2010 clause 14.1.1, 14.1.2.1.3 and Annex H
EN 81-20:2014 clause 5.11.1.1 and 5.11.2.1.2
EN 81-50 clause 5.15
- Test laboratory : None
- Date and number of the laboratory report : None
- Date of type-examination : March – June 2010, rev.1; December 2013 – January 2014,
rev.2; November 2014, Rev.3; September 2016
- Additional document with this certificate : Report belonging to the type-examination certificate
no.: NL10-400-1002-039-11/2 rev.3
- Additional remarks : The printed circuit board is not subjected to the laboratory tests
according to annex F.6 of EN 81-1/2+A3 resp. 5.6 of EN 81-50
- Conclusion : The printed circuit board meets the requirements referred to in this
certificate taking into account any additional remarks mentioned
above.

Amsterdam
Date of issue : 15-09-2016
Valid until : 15-09-2021



ing. J.L. van Vliet
Managing Director



Certification decision by